



# Registration Eextificate

Carpet Name: E612

Licensee: INTERFACE

Licence Number: 1016 Label Number: 24330

ACCS Contract Grading: CEHD 4\*
ACCS Residential Grading: NONE
Suitable for Stairs: Yes

Date Graded: 21-02-2024



**Andrew Martin** Secretary ACCS



CONTRACT

RESIDENTIAL

Administered by the Carpet Institute of Australia Limited ABN 11 006 829 303

PO Box 7172, St Kilda Road, Melbourne Victoria 3004 Tel: (03) 9804 5559

 $\label{lem:email:info@carpetoz.com.au} \bullet \mbox{ www.carpetinstitute.com.au}$ 

This certificate remains the property of the Carpet Institute of Australia Limited.

**Carpet Details:** 

**Company: INTERFACE** 

Label No: 24330 Licence No: 1016 Office No: 7509

4\*

23.81

## Names:

E612

#### **Details:**

Awarded Res Grade: NONE Awarded Con Grade: CEHD Registered On:

21/02/2024 Active: Yes

Date In-Active: Manufacture Method: Tufted Twist Set: N/A Dyeing Method: Melt Dyed #Colours/Designs: 12/ Other Backing Type: Felted: N/A Spinning System: **BCF** N/A Insect Resist Agent:

Master Product:

Filament:

# **Hexapod Scores:**

Texture		Colour		Thickness		
	WA		WA	(mm)	(%)	
1500: 4.0	0.0	4.5	0.0	0.3	6.0	
8000: 3.5	0.0	4.0	0.0	8.0	16.0	

## **ACCS Test:**

	Con	Res	Max
SPM/PH Ratio:	16	16	16
Volume Density:	11.6	11.6	20
Tuft Density:	8.5	8.5	9
Dyn Load:	3.5	3.5	5
Stat Load:	3.5	3.5	5
Soiling Prop:	12	12	14
Abrasion Res:	10	10	10

Sub Total: 65.1 65.1 90 Panel Assess: 14 14 10 Total: 79.1 79.1 100 Calc Residential Grade: REHD2 6\*

Calc Contract Grade: CHD 3\*

#### Test Results:

Pile Mass g/m² (oz/yd²): 882 (26.0)SPM g/m² (oz/yd²): 651.28(19.2) Stated Pile Height (mm): 5.0 Minimum Pile Height (mm): 4.5 Maximum Pile Height (mm): 5.2 Dynamic Loading Loss (%): 0.0 Static Loading Loss (%): 0.0 Tex (g/1000m): 300 Measured Pile Thickness (mm): 4.9 39.4 Machine Gauge (Tufts/dm): Meas Tufts Perp to Selvedge: 40.0 Meas Tufts Para to Selvedge: 43.0 Treated For Soiling Resistance: No Soil Resist Inhibitor: No Stain Resist Inhibitor: No

**Quality Assurance Test:** 

Cut Pile (%): 33.3 Loop Pile (%): 66.7 Panel Assessment Contract: 14 Panel Assessment Residential: 14 Suitable For Stairs: Yes Tile: Yes SheetGoods: No

NBA:100

**NYLON** 

### **Calculations**

Fibre Signature:

Pile Height(mm): 6.4 Tuft Density(per dm²): 1720.0 GSPM(g/m²): 444.7 GSPM (abrasive) (g/m²): 275.0 +0.0 Soiling Propensity: 12.0

## **OAF Values**

OAF: 4.2 Calc Density (+-5%):0.13 0.133 0.14

Benchmarks:

Base Fibre:

RHD1 0 RHD2 3.5 REHD1 3.5 REHD2 3.5

# **Environmental Classification:**

FCS: Level:

B/M P/F Calc 4.9 3 **PASS** Acoustic: Thermal: 36.9 **PASS** 15

VOC:

**TVOC** 0

## Notes:

16/02/2024 - Submitted by Alison Attenborough. 21/02/2024 Panel graded as CEHD(S) 4\*.